



Office of the District Fire Officer,  
Karnataka Fire and Emergency Services Department  
Davanagere Range,  
Chitradurga Fire Station Premises,  
Medehalli road, Chitradurga- 577 527.

Phone:08194-221900

dfochitradurga.ksfes@ka.gov.in



C.No: 10/School/CC/DFO/2025.

Date: 26-05-2025.

To,

The Head Master  
Little Flower International School,  
Near Upparahatti gate village,  
Challakre taluk,  
Chitradurga Dist- 577522.

Sir,

**Sub:-**Issue of 'Fire Safety Compliance Certificate' with respect of fire prevention, fighting and evacuation measures maintained / required at to "**Little Flower International School**", situated at **E-Swathu. no.151000101300120836, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist-577522.**

**Ref:** 1.C.No: 09/school/FSR/DFO/2025 dated: 22-05-2025.  
2. No: 01 /CC/FSTO/CLK/2025 dated: 22-05-2025

-----  
With reference to the subject cited above, "Fire Safety Recommendation" was issued wide above reference to the premises of "**Little Flower International School**", situated at **E-Swathu. no.151000101300120836, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist- 577522.** With a condition to fulfill the recommendations and compliance the same within 03 months.

The management of "**Little Flower International School**", had requested for the compliance report from our department. In this regard the building was re-inspected by the **Fire station officer, Challakere** on **21-05-2025** and they have fulfilled all the Fire precautionary measures. and found all the precautionary measures are in good working condition at the time of inspection.

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing the "Compliance Certificate" to "**Little Flower International School**", situated at **E-Swathu. no.151000101300120836, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist- 577522.** Subject to proper maintenance of fire fighting system in good working condition and at-least 40% of employees should be trained in basic fire fighting at our R.A Mundkur Fire & Emergency Academy, Bannerghatta road, Bengaluru.

**This Compliance Certificate is valid till Dated 19-05-2026 and it is renewable.**

Yours faithfully

*Chellu*  
26/05/25  
District Fire Officer  
Karnataka Fire And Emergency Services  
Chitradurga Dist, Chitradurga-577522

C.No: 09/School/FSR/DFO/2025

Office of District Fire officer,  
Karnataka Fire & Emergency Services,  
Medehalli Road, Chitradurga-577502  
Date-20-05-2025

To,

The Head Master  
Little Flower International School,  
Near Upparahatti gate village,  
Challakre taluk,  
Chitradurga Dist- 577522.

Sir,

**Sub:** Issue of '*Fire Safety Recommendations*' to "*Little Flower International School*", situated at *E-Swathu. no.151000101300120836, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist- 577522.*

**Ref:** No: 01 /LRB/FSTO/CLK/2025 dated: 20-05-2025.

\*\*\*\*\*

With reference to the subject above cited the premises of to "*Little Flower International School*", situated at *E-Swathu. no.151000101300120836, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist- 577522.* was inspected by the *Fire station officer*, Challakere on *01-05-2025* with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

**Details of the Building/Premises.**

01	Name and Address of the Applicant	The Head Master Little Flower International School, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist- 577522.
02	Name and Address of the Premises	E-Swathu. no.151000101300120836, Little Flower International School, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist- 577522. .
03.	Name and Address of the Building Owner	The Head Master Little Flower International School, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist- 577522.



04.	Number of Building	One Building
05.	Number of Floors	Ground and 03 upper floors
06.	<b>Floor-wise details of Occupancy:-</b>	
	Ground Floor	06 class rooms, 01 office rooms, 01 principal room, 01 library, 01 strong room & toilets
	1 <sup>st</sup> floor	04 class rooms, staff room, sports room, computer lab, science lab, electrical room & toilets
	2 <sup>nd</sup> floor	08 class rooms, 01 HM room, 01 Maths lab & toilets.
	3 <sup>rd</sup> floor	04 class rooms, 01 auditorium & toilets
07.	Height of the building	<b>14.56 mtrs</b>
08.	Site area	<b>5899.00 Sq. mtrs</b>
09.	<b>Built-up area of each floor:-</b>	
	Ground floor	886.33 Sq. mtrs
	1 <sup>st</sup> floor	886.33 Sq. mtrs
	2 <sup>nd</sup> floor	886.33 Sq. mtrs
	3 <sup>rd</sup> floor	886.33 Sq. mtrs
10.	Total Built-up area	<b>3545.32 Sq. mtrs</b>
11.	<b>Surrounding properties:-</b>	
	East(side)	Road & the Residential sites
	West(side)	Residential sites
	North(front)	Agricultural land
	South(rear)	Road
12.	<b>Open Space all around the building</b>	
	East(side)	10.00 mtrs
	West(side)	02.80 mtrs
	North(front)	08.00 mtrs
	South(rear)	04.80 mtrs
	<b>Allowed Setbacks ( open space) should be maintained free from further obstruction/construction.</b>	



**B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-**

<b>Sl. (01)</b>	<b>Details (02)</b>	<b>Existing (03)</b>		<b>Recommendations (04)</b>
<b>01.</b>	Accessibility to the premises	The premises is abutting 06.00 mtrs wide road on Eastern side of the premises. The road is hardened to carry the weight of the weight of 45,000 Kg's.		Adequate
<b>02.</b>	Number of Entrances	01 entrance of 4.80 mtrs wide.		--
<b>03.</b>	Diesel generator	Provided one diesel generator of 15 KV.		Complied.
<b>04.</b>	Number of Staircase	No of staircase	01	The staircase must be maintained free from obstruction.
		Width of the staircase	01.70 mtr	
		Width of threads	0.30 mtr	
		Height of risers	0.12 mtr	
		No of risers per flight	11	
		Height of the hand drill.	1.00 mtr	
		Head roof clearance	3.00 mtr	
<b>05.</b>	Portable Extinguishers	Not Provided		<b>Not Complied</b>
				A. One water mist extinguisher of 9 ltrs capacity should kept near staircase landing.
				B. One mechanical foam extinguisher of 9 ltrs capacity & One ABC type extinguisher of 6 kgs capacity should be provided near diesel generator.
				C. One CO2 type fire



			<p>extinguisher, of 4.5 kgs capacity should be provided near each electrical panel board &amp; electrical room.</p> <p>D. One ABC type fire extinguisher of 06 kgs capacity should be located as to be available within 15 mtrs. radius.</p>
06.	Hose reel hose system	Not provided	<p><b>Not Complied</b></p> <p>One Hose Reel Hose near the staircase (<b>One hose reel hose system for every 1000 Sq. mtrs.</b>). The hose reel hose of min 19 mm size and of 30.00 mtrs length shall be provided to reach the farthest point of each floor and shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing.</p>
07.	Terrace tank over respective tower terrace.	Provided one terrace tank of 4000 ltrs. Capacity	<p><b>Not Complied</b></p> <p>The system should be connected to an over head tank of 5,000 ltrs capacity.</p> <p><b>(The water tank should be kept exclusively fire fight purpose)</b></p> <p><b>Note:</b> If the existing building is not capable of sustaining the weight of 5,000 / 10,000 ltrs tank capacity provision shall be made to provide water tank on the side of the building with support from ground level by providing RCC column structure or MS Column structure.</p> <p>If there is no option to provide even the above mentioned overhead tank provision shall be made to provide</p>



			underground water tank of capacity with submersible pump of 5-7 HP capacity.
<b>08.</b>	At the terrace tank level with minimum pressure of 3.5 kg/cm <sup>2</sup>	Not provided	The system should be connected to an booster pump of 450 LPM or of 5 HP capacity. <b>Further the system should be connected to an alternative source of power supply.</b>
<b>09</b>	Escape routes	Not marked	<b>Not Complied</b> Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.
<b>10</b>	Fire Order (Fire safety plans)	Not displayed	<b>Not Complied</b> A notice board indicating the action to be taken by the employees in case of any emergency should be displayed along with the telephone number of nearest fire station Challakere Fire Station i.e. 08195-222400 and the telephone number of nearest ambulance service & Police station.
<b>11.</b>	No Smoking board	Not displayed	<b>Not Complied</b> COTPA Sec-4 direction No Smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry / exit of the each floor.
<b>12</b>	Fire Siren	Not installed	<b>Not Complied</b> A Fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.



13	Nominate one fire Nodal officer.	Not Nominated	A fire nodal officer shall be nominated either from teaching or non teaching staff.
14	Fire Fighting Training	Not Imparted	At least 40% of the employee/staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore.
15.	<p><b><u>Fire precautionary measures :-</u></b></p> <ul style="list-style-type: none"> <li>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory &amp; electrical sum panel premises.</li> <li>B. Accumulation of combustible waste in and around the premises should be avoided.</li> <li>C. The exit ways shall be always kept clear without any obstruction.</li> <li>D. Liquefied petroleum gas should not be stored in the building.</li> <li>E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.</li> <li>F. During the class hours the class room doors shall not be locked from inside to out side.</li> <li>G. As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordinate with fire service department.</li> </ul>		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "***Fire Safety Recommendation***" to existing building of "***Little Flower International School***", situated at ***E-Swathu. no.151000101300120836, Near Upparahatti gate village, Challakere taluk, Chitradurga Dist- 577522.*** is subjected to condition and compliance of the above recommendations in the column-4 of serial-B within 03 months and compliance to undersigned.

This "***Fire Safety Recommendation***" is valid for only one year from the date of issue.

**All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life Safety will have to be complied with mandatory.**

Yours Faithfully

*Spurk 20/05/25*  
 District Fire Officer  
 Karnataka Fire And Emergency Services  
 Chitradurga Dist, Chitradurga-577522